

"Design, Supply, Installation, Testing and Commissioning and CAMC for 3 years for Active Power Filter System/DSTATCOM for Power Factor Improvement in GMRCL Traction Network of Ahmedabad Metro Rail Phase-I & II".

Tender No. GMRC/O&M/PF Improvement/R/2026

ADDENDUM NO: 1, DATED: 20/8/2026

S. N.	Vol	Clause	Page no.	Clause Description (relevant portion) as existing in the Bid Documents	Clause Description (relevant portion) as amended now to be read as
1	II	ERTS Clause 2.1 Table 2.1 Sr. No. 8	17 of 28	Network voltage variation ±10%	Network voltage variation +10% , -15%
2	II	ERGS Clause 1.10.3 Table Sr No. 1	12 of 21	Ambient Temperature 35 °C	Ambient Temperature 45 °C