

Design, Supply, Installation, Testing, Commissioning and Training for Clean Agent based panel flooding protection system for Traction system of Surat Metro Rail Project Phase-I for Gujarat Metro Rail Corporation Limited					
Tender No:- GMRC/TR/GFS/SURAT/2026					ADDENDUM NO: 1, DATED: 24/08/2026
S. N.	Vol	Clause	Page no.	Clause Description (relevant portion) as existing in the Bid Documents	Clause Description (relevant portion) as amended now to be read as
1	II	TS Clause 1.3.1.2	4 of 9	New Clause to be added	The FK-5-1-12 clean agent shall be stored only in PESO-approved gas cylinders fitted with PESO-approved valve assemblies. The valve assembly shall be type-tested as per EN ISO 17871, as applicable and accepted by PESO. Bidder shall submit valid manufacturer's test and inspection certificates and a test certificate from a Government-approved/NABL-accredited third-party laboratory for the cylinders and valves.