

Design, Supply, Installation, Testing, Commissioning and Training for Clean Agent based panel flooding protection system for Traction system of Surat Metro Rail Project Phase-I for Gujarat Metro Rail Corporation Limited

Tender No:- GMRC/TR/GFS/SURAT/2026

SN	Vol	Vol Name	Clause No.	Page No.	Tender Condition	Bidder's Query	GMRC's Clarification, dated: 24/08/2026
1	II	TS	-	1 to 9	Chapter-1	We are providing PESO Approved Valve for all our system by default and PESO Approved Cylinder if desired by Client. Moreover, PESO Approved Cylinders are not mandatory to be used with Pre-Engineered Systems	Refer SN. 1 of Addendum no. 1
2	II	TS	-	1 to 9	Chapter-1	We are providing DLP System with all the key components of the system such as polymer tube, clean agent and Pressure Switch are UL Listed	Bidder's understanding is correct. For More clarification refer tender clause 1.1.2 of TS Tender conditions are self explanatory. Tender conditions prevails.
3	II	TS	-	1 to 9	Chapter-1	We are providing ILP System with polymer tube, clean agent and Pressure Switch are UL Listed and all the cylinder sizes as specified in the Tender.	Bidder's understanding is correct. For More clarification refer tender clause 1.1.2 of TS Tender conditions are self explanatory. Tender conditions prevails.
4	II	TS	-	1 to 9	Chapter-1	The cylinder shall be PESO (Petroleum Explosive Safety Organization) approved as per Gas Cylinder Rules.	Refer SN. 1 of Addendum no. 1